

Technical Analysis of the 505 Pitting Project - Surface in the Kamoto Mine

TSHIBWABWA KASONGO Obed¹, MAZONO ZULBAL Eric², KATOKA KITUBA Alain³,
MPEYE ONU Christian⁴, KAUMBA Emmanuel⁵

¹Teaching assistant at the Higher Institute of Applied Techniques of Lubumbashi

²Teaching assistant at the Higher Institute of Applied Techniques of Lubumbashi

³Teaching assistant at the Higher Institute of Applied Techniques of Lubumbashi

⁴Head of teaching work at the Higher Institute of Applied Techniques of Lubumbashi

⁵Head of teaching work at the Higher Institute of Applied Techniques of Lubumbashi

Abstract: In order to analyze the 505-surface dewatering project in the KAMOTO mine, we quantified all the water inflows to zone 5 in order to allow us to properly size our new dewatering circuit. The maximum inflow to zone 5 is 890 m³/h. For circuit sizing; it was subdivided into two sections. For the first section (505-355), we obtained as total head losses equal to 10.98 m, which gives us a manometric height of 160.98 m. We have chosen 4 Flowserve pumps of the 150 NM type with a nominal flow rate of 250 m³/h and a head of 250 m which will be installed in parallel and 1 spare pump of the same type. Thus the operating point of a pump is (400; 150) and pumps in parallel is (1480; 175). As for the second section, the losses are 7.6 m which gives a height gauge of 362.6 m and we choose 2 Flowserve 201 NM type pumps with a nominal flow rate of 450 m³/h with a manometric head of 400 m which will be placed in parallel and 1 pump of the same type in reserve. Thus the operating point is (280; 355) for one pump and for the pumps in parallel (550; 360). And after sizing the decanter with flocculant, we obtained the following results: the lateral surface of the decanter is 423.81; the width 8 m and the length 50 m. To make it easier for the decanter to be cleaned at the same the moment the water was pumped, the settling tank was split into compartments; therefore the cleaning will take place without stopping the dewatering pumps. It will be done using BRAVO 400 type mud pumps.

1. Introduction

The KAMOTO underground mine aims to ensure the production Planned 180,000 TS/year in complete safety. For this, there are several problems that will have to be solved in order to carry out this annual planning. Among these various problems, there is drainage.

The problem being based on the 505 dewatering of the KAMOTO underground mine, it will be a question of:

- Assess the quantity of water inflow to this area;
- Size the new circuit;
- Design the relay station (decanter + thin layer);
- Size the decanter (relay station); - provide for the cleaning of the decanter.

Water Influx Assessment

The KAMOTO underground mine is supplied with water by:

- The KAMOTO Etang aquifer
- The KAMOTO South aquifer
- The KABULUNGU tablecloth
- The KAMOTO Roof ply
- The KOV tablecloth

In addition to these five aquifers, there are waters that come from hydraulic backfilling.

So to arrive at sizing our new circuit, we will be obliged to go through a quantification of inflows throughout the underground mine as well as those of the treated area. The influx of water that goes to the underground mine of KAMOTO is given in the tables below:

Table 1: Kamoto Etang aquifer inflow

Sources of water			AQUIFER KTO ETANG 2020-2021											
Level	Locate	Description	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	June-14	July-14	Aug-14	Sept-14
N.235	CH W	seepage	0,5	0,5	0,5	0,3	0,5	0,5	0,5	0,5	0,3	0,3		
N.265	CH W	Seepage	1	1	1	3,7	3	3	3	3	2,7	2,5		
N307	TUNA	Crack	529	526	526	444	355	348	365	327,42	308	291	216	205
N385	Ac32CTS	leak			2	2	2	2	2	2	2	1,72	1,6	1,88
N385	AccBino	leak	25,86	13,56	0	0	0	0	0	0	0	0	7,48	7,13
N400	Ac20	seepage	1	1	1	1	1	1	1	1	1	1	1,6	1,4
N403	ChimneySimba	seepage	Nm	Nm	Nm	Nm	Nm	Nm					15	13
N415	CTS	seepage		Nm	Nm	Nm	Nm	Nm	8,77	8,67	9	9	2	1,4
N415	OBI	Seepage		Nm	Nm	Nm	Nm	Nm	12,57	13,01	13,71	13	7,81	10,13
N415	AC 24 /CTS	seepage				25,15			13,59	16,48	14,72	15,42	13,24	13,12
N.425	ETANG	obturator												
N.430	ETANG	Hole		Nm	Nm	Nm	Nm	Nm					2	1

Volume 11 Issue 4, April 2022

www.ijsr.net

Licensed Under Creative Commons Attribution CC BY

N460	Rampe 17	Seepage			18	3,85	23	21					21	23
N445	Main access North	Crack	5,25	16,42	0	0	12,37	11,78	2	2	4	6	12	13
N445	Rampe 18	Seepage			4	9	5	5	5	6	5,71	5	12,77	6,41
N460	Z1 OBI	hole	16,11	28,13	28	2	28,13	27,89					28,13	28,14
N460	Rp460-445	Seepage	1	1	1	1	1	1	1	1	1	1	1	1
N475	CTS	seepage	1	1	1	1	1	1	1	1	1	1	1,2	1
N.490	INCLINE16	Crack	1.9	1.8	2	2	9	8	2	2	2	2	0	0
N505	T3/RP505	borehole			0	0	1,8	1,5	0	0	1,2	1	0	0
N520	T3 Wuna	obturator	0,5	0,5	0	0	0,5	0,5	0	0	0	0	0	0
N.460	ETG OBS	Dry	0	0			3	0	0				4	5
SUB TOTAL OF DIRTY WATER			583.12	590.91	584.50	498.85	443.30	432.17	417.43	384.08	366.34	349.94	346.83	331.61

Table 2. Hydraulic backfill inflow: **BACKFILLING WATER**

Level	Locate	Description	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	June-14	July-14	Aug-14	Sept-14
Sources of water			Flow (m3/h)											
N505	Etang North T8-T13	Seepage	50	51	45	56	57	64	55	56	80	48	60	60
N505	CH11-12 -Zone1 OBI	Seepage	50	49	48	52	55	51	47	53	60	47	45	74
N505-490	T0-T5 Etang North OBI	seepage	50	49	47	43	63	86	57	44	39,32	45	65	33
SUBTOTAL OF BACKFILLING HYDRAULIC			150	149	140	151	175	201	159	153	179,32	140	170	167

Table 3: KOV aquifer inflow

AQUIFER KOV 2020-2021														
Sources of water			Flow (m3/h)											
Clear water														
Level	Locate	Description	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	June-14	July-14	Aug-14	Sept-14
N.276	INCL 4	obturator	Dry	Dry	Dry	0	0	0	0	0	0	0	0	0
N.285	INCL 4	obturator	0	0	Dry	0	0	0	0	0	0	0	0	0
N.273	CHE	obturator	Dry 0	Dry	13	6,3	4,16	15,78	15,12	8,9	12,01	12	15	12
N.300	INCL 3bis	Seepage		0	Dry	0	0	0	0	0	0	0	0	0
N.300	INCL 4bis	obturator	Dry 0	Dry	Dry	0	0	0	0	0	0	0	0	0
		Seepage		0		0	17	15,15	16,15	13	12	13	0	0
N.330	CHE	obturator	65,12	54,98	60,4	60	61	65	63	55	41	73	34,85	4
		Seepage	1	1	1	1	1	1	1	8	7	9	41	41
N.345	CHE	obturator	132,47	132,23	144	144	142	140	138	135	131	130	75,58	90,02
		Seepage	115,7	122,7	82	60	52,35	47,7	51	49	52,1	55	102	102
N370	CHE/incline9	Leak	12	12	13	13	12	12	11	11	9,81	9,12	59,49	51
N415	CHE RA400	Leak	13,25	10,11	11	11	10,2	11	10	8	8	53	53	1
N.432	INCL9(CON12)	obturator	248,28	201,3	221	224	204,31	206	217	212	199,02	8	62,16	121
		Seepage	2	2	25	0	0	0	0	0	0	0	126	1,8
TOTAL OF KOV(Clean water)			589.82	536.32	570,4	519,3	504,02	513,63	522,27	499,9	471,94	488,12	444,88	428.02

Table 4: Inflow from the South Kamoto aquifer

AQUIFER OF KTO/SUD 2020-2021														
SOURCES OF WATERS			Flow (m3/h)											
Level	Locate	Description	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	June-14	July-14	Aug-14	Sept-14
Clear water														
N.207	PUITS 4	obturator	93,45	96,23	90,97	111	91,36	95,76	95,93	95,36	94,38	76,2	61,35	54
N.345	RA200	Seepage	11,12	12,78	15	4,3	15,39	4,6	4,2	4,9	4,5	4	1	1
N.345	RA TOGO	obturator	3,08	3	10,58	30	3	5	5	5	5	5	5	5
		Seepage	22,89	24,71	28,33	2,5	16,2	13,5	14,6	15,02	12,1	13,12	11	12
N.345	RA400	obturator	1	1	4,27	2	1	1	1	1	1	1	1	1
		Seepage	15,47	16,09	10,96	19,41	23,59	24,7	22,9	19,13	11,39	10,78	8	6
N.345	RA600	Seepage	0,5	0,5	0,5	0,5	0,5	0,5	0,3	0,3	0,3	0,3	0,5	0,5
TOTAL OF KTO/SUD (clear water)			147.51	154.31	160.93	169,71	151,24	145,06	144	140,71	128,67	110,4	87,85	79.5

Table 5: Kabulungu groundwater inflow

SOURCES OF WATERS			AQUIFER OF KABULUNGU 2020-2021											
Level	Locate	Description	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	June-14	July-14	Aug-14	Sept-14
Clear water			Flow (m3/h)											
N.357	ANC/SON	borehole	237.07	230.12	230,12	200	213,12	207	198	164	199	206	243	263
N.357	AP510W	borehole												
N.357	RP510W	obturator												
N.357	R 575	Seepage												
N.357	CAS SCH	crack	300	300.1	300,1	300	318,62	311	234	218,26	226	252	206	197
TOTAL OF KABULUNGU (clear water)			537.07	530.22	530,2	500	531,74	518	432	382,28	425	458	449	460

Table 6: Groundwater inflow from KAMOTO Roof

SOURCES OF WATER			AQUIFER OF KTO/TOIT 2020-2021											
Level	Locate	Description	Oct-13	Nov-13	Dec-13	Jan-14	Feb-14	Mar-14	Apr-14	May-14	Jun-14	Jul-14	Aug-14	Sep-14
Sources of water			Flow (m3/h)											
N.150	INCL 1-2	Hole	20,57	21.39	16,47	18,95	17,65	1,91	2,1	1,24	1,5	19,5	4,18	3,2
		Seepage			5	6								
N.207	CH Mayi	Seepage	1	1	1	1	6,3	1,72	1,89	10,12	7,2	2,5	0,5	0,5
N.213	INCLINE2	Seepage	1	1	1	1	1	1	1	1	1	1	0	
N.240	INCLINE2	Seepage	1	1	1	1	1	1	1	1	1	1	0	
N.328	CH.LAKI	Seepage	1	1	1	1	13,97	1	1	1	1	1	0	
N.357	Puits3	borehole	3	3	3	3	4	4	3	3	4	4	3,5	3,22
N.425	ACC 180 W	Leak			20	5		5	6	6	7,2	11,13	21,74	20,12
N505	Rb1	Seepage	22	23.07	1	1	23,07	20,78	21,5	20,98	20,21	19,48	23,94	23,6
		borehole	1	1	6	3	16,76	17,13	20,14	22	10,8	12,1	11,78	9,56
N.505	RB2	Seepage	20,85	21.2	35	14	21,2	20,1	20	18	18	19	12,59	12,72
N505	Chimney 1300	Seepage	5	5	5	1	5	5	5	5	5	5	2,5	2,5
N505	Rampe22	Holeleft	25,12	21.13	1	1	1	0	0	0	0	0	0	0
N505	Rampe22/D29 S	Leak			1		19,69	18,99	11,55	8,75	8,17	12,29	0	0
N505	R21/D29M		59,2	55.68	10	8,71	32,94	31,73	31,85	32	33,56	30,44	35	36,7
N505	D29/R1	hole			0	0	20,57	21,13	24,97	21,23	7,15	28,18	25	22,7
N505	D29/Acc OBI 2	holes			61	19,73	3	2	1	1	1	1	15,05	13,78
N505	Rampe21/R5	Seepage	1,5	1.3	0	0	4	5	4	3,75	2	2	1	1
TOTAL OF KTO/TOIT			162.15	156.77	168,47	85,39	191,15	157,49	156	156,07	128,79	169.62	156.78	149.6
GENERAL TOTAL			2169.67	2117.53	2154,52	1924,25	1996,45	1967,35	1830,32	1716,02	1700,01	1716.08	1655	1616

Table 7: Inflow from the Fallen Zone to Zone 5

Sources of water			Afflux d'eau de la zone eboulée vers la zone 5 (505 L)											
Level	Locate	Description	Flow (m3/h)											
			Oct -13	Nov 13	Dec -13	Jan -14	Feb -14	Mar -14	Apr -14	May -14	June -14	July -14	Aug -14	Sept -14
N505	GL1 sond front	Borehole	0	0	0	0	0	0	0	0	0	0	0	0
N.505	GL1/SOND parent	Borehole	0	0	0	0	0	0	0	0	0	0	0	0
N.505	D29/Rampe 22 Sud	Crack (faille)	0.5	0.5	0.5	0.5	0	0	0	0	0	10	0	0
N.505	Rampe 22 Toit	Borehole	3	3	3	3	0	3	0	0	5	50	0	0
N.505	Rampe 22/CON 1	Borehole	85	83	83	83	80	65	29	28	95	76	81	78
N.505	KUMBWA	Seepage	65	65	65	65	65	65	65	65	85	65	65	65
GENERAL TOTAL			153.5	151.5	151,5	151,5	145	133	94	93	185	201	146	143

Table 8 : General inflow from KAMOTO underground mine

	KTO/ETANG	KTO/KOV	KABULUNGU	KTO/SUD	KTO/TOIT	BACKFILL	ZONE EBOULEE
Oct-20	582,12	589,82	537,07	147,51	162,15	150	153,5
Nov-20	590,91	536,32	530,22	154,31	156,77	149	151,5
Dec-20	584,5	570,4	530,2	160,93	168,47	140	151,5
Jan-21	498,85	519,3	500	169,71	85,39	151	151,5
Feb-21	443,3	504,02	531,74	151,24	191,15	175	145
March-21	432,17	513,63	518	145,06	157,49	201	133
Apr-21	417,43	522,27	432	144	156	159	94
May-21	384,08	499,9	382,28	140,71	156,07	153	93
Jun-21	366,34	471,94	425	128,67	128,79	179,32	185
Jul-21	349,94	488,12	458	110,4	139,62	140	201
Aug-21	346,83	444,88	449	87,85	156,78	170	146
Sep-21	331,61	428,02	460	79,5	149,6	167	143

TOTAL(m3/h)	5328,08	6088,62	5753,51	1619,9	1808,3	1934,3	1748
total flow (m3/h)	24280,7						
average flow (m3/h)	3468,671429						

Since the Kamoto mine is large, comprising several areas, our field of action is limited only to the dewatering Zone 5, level 505. Hence it will be a question of quantifying only the influx of water to zone 5 and not for the entire mine.

Water inflows to zone 5 come from the following locations:

- Kamoto roof ply
- Hydraulic backfilling (Back Fill)
- The collapsed or collapsed area which is fed by water inflows from the overflows of holding tanks and settling tanks of the main drainage 369, overflows of the holding tanks of the secondary drainage 465, leaks on the pipes, on the walls backfilled chambers, collapses of the sludge walls (hydraulic backfilling) and seepage in the walls of the galleries.

The influx of water that goes towards the treated area in the mine Kamoto underground are given in the table below:

Table 9: Influx from Zone 5

	<i>KTO/TOIT</i>	<i>BACKFILL</i>	<i>Zone éboulee</i>
Oct-20	162.15	150	153
Nov-20	156,77	149	151.5
Dec-21	168.47	140	151.5
Jan-21	85.39	151	151.5
Feb-21	191.15	175	145
Mar-21	157.49	201	133
Apr-21	156	159	94
May-21	156.07	153	93
Jun-21	128.79	179.32	185
Jul-21	169.62	140	201
Aug-21	156.78	170	146
Sep-21	149.6	167	143
TOTAL (m3/h)	1838.28	1934.32	1747.5
Total flow (m3/h)	5520.1		
Average flow (m3/h)	460.01		

The average inflow rate in Zone 5, 505 L is:
 $(1838.28 + 1934.32 + 1747.5) = 460.01 \text{ m}^3/\text{h}$

In the rest of our work, as it is a question of sizing a new pumping circuit we will not use the average flow but rather the maximum flow in red (Cfr Table .2) of each aquifer supplying zone 5 during a period of 12 months (i.e. from October 2020 until September 2021). The maximum flows for each aquifer towards zone 5 are:

- for Kamoto roof: $Q = 191.15 \text{ /h}$
- for hydraulic backfilling: $Q = 201 \text{ /h}$
- for the collapsed area: $Q = 201 \text{ /h}$ Which gives us a maximum flow of:

$$Q_{\max} = 191.15 + 201 + 201 = 593.15 \text{ /h}$$

To the hydrogeology department of the Kamoto underground mine, for all Sizing, a safety factor of 1.5 is used.

Then we will have as the maximum value of the flow the following:
 $= 1.5 \times 593.15 = 889.725 \text{ m}^3/\text{h}$

And we will take as value = 890 /h

The dewatering rules recommend that the water pumping capacity per unit of time is greater than the water inflows of this same unit. At the limit where there is a tie, the water level will just be maintained at its starting point with all the risks incurred. And if not, drowning will be imminent if effective measures are not taken.

1.1 Circuit Sizing

A pumping circuit is characterized by a geometric height (Hg) (summation between the suction height and the discharge height), a length (L), the flow rate of the fluid (Q) and the components that constitute it.

The length of the piping as well as the accessories of the circuit creates pressure losses (ΔH). Thus, at discharge, the pump must overcome these pressure drops to discharge the fluid to the desired location.

With regard to the dimensioning, it is a question of pumping the water from zone 5, directly towards the surface on a path already evaluated using the Autocad software which is 2050 m.

The new circuit will start from level 505 directly to the surface via the following route:

- from GL3 (Holding) at level 505 to level 425 via chimney Rb 21 which connects the two levels;
- at 425, the circuit will take ramp 25 to level 355 where a decanter + outfit will be installed;
- from 355 to level 207 via chimney Rb 19 connecting the two levels;
- and 207 to the surface through boreholes.

The new circuit will be divided into two parts or sections, namely:

- From 505 L up to 355 L over a length of 1200 m with a geometric height of 150 m
- 355 L to the surface over a length of 850 m with a geometric height of 355 m

The figure below shows the diagram (in green) of the 505 dewatering project up to the surface.




Figure 3: Diagram of the 505 dewatering project - surface

1.1.1 First section

We have as data:

- the length = 1200 m
- height difference = 150 m
- the maximum flow = 890

a) The speed of water circulation in the pipes

A speed of between 1.5 and 2.2 m/s is chosen to minimize the load losses. And if the water is very loaded with solid particles, it is advisable to take speeds close to 2 m/s. For our case we have chosen a speed of 2 m/s because the water in zone 5 is loaded with solid particles.

b) The diameter of the pipe

The diameter of the pipe is conditioned by the flow velocity and the flow. It is deduced from the following expression:

$$(m) \text{ (III.3)}$$

$$= + 0.025 (m) \text{ (III.4)}$$

With :

- : diameter of the discharge pipe []
- : diameter of the suction pipe []
- : the pumping rate []
- V: average water flow speed in the pipe [] In our case, the diameters are:
= 0.3968 m or 16 inches
= + 0.025 = 0.3968 + 0.025 = 0.4218 m or 17 inches

c) Load losses

The movement of a fluid in a pipeline implies the existence of a force that generates its movement. This force results from a pressure upstream of the network, which is commonly called the head of head.

This load height is therefore variable depending on the location of the circuit.

In addition, under the effect of the friction of the fluid on the walls of the pipes and the obstacles encountered, this initial load decreases throughout the course. This is referred to as head losses.

The pressure drops depend on the material, the flow rate, the shape of the route, diameter and length of the pipes.

There are two types of head losses:

- Linear head losses due to friction of the fluid on the walls
- Singular head losses due to mishaps in the pipelines and obstacles (elbows, valves, etc.)

Linear pressure drops

They occur throughout the conduct and are deduced by the Darcy-Weisbach relation:

$$[m] \text{ (5) With:}$$

λ : Darcy coefficient of friction. It is a function of the flow regime translated by the Reynold number (Re) given by the following relationship:

$$Re = (6) \text{ With:}$$

V: Flow velocity []

D: Pipe diameter [m]

Kinematic viscosity [] for water =

L: Pipe length [m]

NB: The conditions necessary to determine the type of flow regime according to the Reynold number (Re) as well as the determination of the pressure loss coefficient (Δ) for each regime are as follows:

if $Re = 2300$: the regime is laminar hence:

$$\Delta = Re/64 \quad (7)$$

if $2300 < Re < 100,000$: the regime is turbulent smooth

$$\Delta = 0.316. \text{ (BLASIUS formula)} \quad (8)$$

if $Re > 100,000$: the regime is rough turbulent

$$\Delta = 0.0032 + 0.221. \text{ (NIKURADSE formula)} \quad (9)$$

With:

- : dynamic viscosity kg/ms

- : density of Kamoto water 1.154. kg/

So

$$Re = 2 \cdot 0.4218 / 8.6655 \cdot 10^{-7} > 2300$$

So we're dealing with a rough turbulent regime

The value of the linear pressure loss coefficient is:

$$\Delta = 0.0032 + 0.221. = 0.0032 + 0.221. (= 0.0116)$$

So :

Δh

$$\Delta h = \lambda \cdot L / D \cdot (V \cdot V) / 2g = 0.0116 \cdot 5 / 0.4218 \cdot 2.2 / 2 \cdot 10 = 0.0275 \text{ m}$$

$$\Delta h_{ref} = \lambda \cdot L_{ref} / D_{ref} \cdot (V_{ref} \cdot V_{ref}) / 2g; Re = (V_{ref} \cdot V_{ref}) / \nu$$

$$Re = (2 \cdot 0.3968) / (8.6655 \cdot 10^{-7}) = 915815.5906 > 2300$$

So the regime is turbulent rough

The value of the linear pressure loss coefficient will be:

$$\lambda = 0.0032 + 0.221. = 0.0032 + 0.221. (= 0.0117)$$

Δh

$$\Delta h_{ref} = \lambda \cdot L_{ref} / D_{ref} \cdot (V_{ref})^2 / 2g = 0.0117 \cdot 1200 / 0.3968 \cdot 2.2^2 / 2 \cdot 10 = 7.0766 \text{ m}$$

Singular pressure drops

They occur when the fluid passes through the accessories of the pipe, such as elbows, valves, section changes, etc.

They are given by the formula below:

$$h_{sing}^v = n \cdot (k \cdot v^2) / 2g \quad [m] \quad (11)$$

With :

n: number of accessories;

k: the pressure drop coefficient;

v: liquid velocity (m/s)

g: acceleration due to gravity (m/s²) Our circuit will include:

18 bends including: 9 bends of 90°; 5 elbows of 60° and 4 elbows of 22°

1 check valve

2 valves

1 strainer

Then the singular head losses become:

For a check valve (k=1):

$$h_{sing1}^v = n \cdot (k \cdot v^2) / 2g = 1 \cdot 1.2 \cdot 2.2 / 2 \cdot 10 = 0.2 \text{ m}$$

For 2 valves (k=1.5):

$$h_{sing2}^v = n \cdot (k \cdot v^2) / 2g = (2 \cdot 1.5 \cdot 2.2^2) / 2 \cdot 10 = 0.6 \text{ m}$$

For a strainer (K=1):

$$h_{sing1}^v = n \cdot (k \cdot v^2) / 2g = 1 \cdot 1.2 \cdot 2.2 / 2 \cdot 10 = 0.2 \text{ m}$$

For 9 bends of 90° (k=1.2):

$$h_{sing4}^v = n \cdot (k \cdot v^2) / 2g = (9 \cdot 1.2 \cdot 2.2^2) / 2 \cdot 10 = 2.16 \text{ m}$$

For 5 elbows of 60° (k=0.60):

$$h_{sing5}^v = n \cdot (k \cdot v^2) / 2g = (5 \cdot 0.6 \cdot 2.2^2) / 2 \cdot 10 = 0.6 \text{ m}$$

For 4 elbows of 22° (k=0.15):

$$h_{sing6}^v = n \cdot (k \cdot v^2) / 2g = (4 \cdot 0.15 \cdot 2.2^2) / 2 \cdot 10 = 0.12 \text{ m}$$

= + + + + +

$$= 0.2 + 0.6 + 0.2 + 2.16 + 0.6 + 0.12 = 3.88 \text{ m}$$

So the total losses are:

$$= + + = 0.0275 + 7.0766 + 3.88 = 10.98 \text{ m}$$

Determination of manometric height

Manometric height means the sum of the geometric height and the pressure drops caused by internal friction which is formed when the liquid passes through the pipes, the pump and the hydraulic accessories. It is given by the following relationship:

$$= + (12) = 150 + 10.98 = 160.98 \text{ m}$$

Choice of pumps

The choice of pumps for this section is conditioned by the flow maximum and the head obtained above.

The pump to be chosen must have a flow greater than 890 /h and a head greater than 160.98 m.

Depending on the above results, we choose the FLOWSERVE 150 NM type pump which has a nominal flow rate of 250 m³/h and a head of 250 m.

We will take 4 pumps which will be put in parallel of which 3 will work 24/24 h and one 12/24 h - 1 pump in reserve of the same type.

Determination of operating point 1

$$H = H_g + \Delta h. \quad \left[\left(\frac{Q_i}{Q_{tot}} \right) \right]^2 \quad (12)$$

With $Q_{tot} = (250 \times 4) = 1000 \text{ m}^3/\text{h}$

Table 10: Calculation of head losses at different flow rates for section 1

Qi	Hg	h	Qtot	Hm
0	150	10.9841	1000	150
30	150	10.9841	1000	150.00989
60	150	10.9841	1000	150.03954
90	150	10.9841	1000	150.08897
120	150	10.9841	1000	150.15817
150	150	10.9841	1000	150.24714
180	150	10.9841	1000	150.35589
210	150	10.9841	1000	150.4844
240	150	10.9841	1000	150.63268
270	150	10.9841	1000	150.80074
300	150	10.9841	1000	150.98857
330	150	10.9841	1000	151.19617
360	150	10.9841	1000	151.42354
390	150	10.9841	1000	151.67068
420	150	10.9841	1000	151.9376
450	150	10.9841	1000	152.22428
480	150	10.9841	1000	152.53074
510	150	10.9841	1000	152.85696
540	150	10.9841	1000	153.20296

570	150	10.9841	1000	153.56873
600	150	10.9841	1000	153.95428
630	150	10.9841	1000	154.35959
660	150	10.9841	1000	154.78467
690	150	10.9841	1000	155.22953
720	150	10.9841	1000	155.69416
750	150	10.9841	1000	156.17856
780	150	10.9841	1000	156.68273
810	150	10.9841	1000	157.20667
840	150	10.9841	1000	157.75038
870	150	10.9841	1000	158.31387
900	150	10.9841	1000	158.89712
930	150	10.9841	1000	159.50015
960	150	10.9841	1000	160.12295
990	150	10.9841	1000	160.76552
1020	150	10.9841	1000	161.42786
1050	150	10.9841	1000	162.10997
1080	150	10.9841	1000	162.81185
1110	150	10.9841	1000	163.53351
1140	150	10.9841	1000	164.27494
1170	150	10.9841	1000	165.03613
1200	150	10.9841	1000	165.81171
1230	150	10.9841	1000	166.61785
1260	150	10.9841	1000	167.43836

1290	150	10.9841	1000	168.27864
1320	150	10.9841	1000	169.1387
1350	150	10.9841	1000	170.01852
1380	150	10.9841	1000	170.91812
1410	150	10.9841	1000	171.83749
1440	150	10.9841	1000	172.77663
1470	150	10.9841	1000	173.73554
1500	150	10.9841	1000	174.71423
1530	150	10.9841	1000	175.71268
1560	150	10.9841	1000	176.73091
1590	150	10.9841	1000	177.7689
1620	150	10.9841	1000	178.82667
1650	150	10.9841	1000	179.90421
1680	150	10.9841	1000	181.00152
1710	150	10.9841	1000	182.11861
1740	150	10.9841	1000	183.25546
1770	150	10.9841	1000	184.41209
1800	150	10.9841	1000	185.58848

Figure (2.) below gives us the curves of the flows according to the manometric heights of the network (in red), the pump (in blue) and the pumps placed in parallel (in green).




Figure 2: Section 1 operating point

Thus we obtain our operating point of a pump at (400; 150) and that of the pumps placed in parallel at (1480; 175) in the figure above.

1.2 Second section

We have as data:

- The length = 850 m
- Height difference = 355 m
- The maximum flow = 890

a) The speed of water circulation in the pipes

We have always chosen a speed of 2 m/s because we assume that the water is loaded with solid particles.

b) The diameter of the pipe

The water speed and the max flow does not change, we will take always $Dr = 0.3968$ m or 16 inches and $Da = 0.4218$ m or 17 inches.

c) Load losses

Linear pressure drops

$Re = 2300$ the regime is turbulent rough

The value of the linear pressure loss coefficient is:

$$\lambda = 0,0032 + 0,221 \cdot Re^{-0,237} = 0,0032 + 0,221 \cdot (973515,6656)^{-0,237} = 0,0116$$

$$\bullet \text{ Then } h_{lin\ asp} = \lambda \cdot \frac{L_a}{D_a} \cdot \frac{V_a^2}{2g} = 0,0116 \cdot \frac{5}{0,4218} \cdot \frac{2^2}{2 \cdot 10} = 0,0275 \text{ m}$$

$$\bullet h_{lin\ ref} = \lambda \cdot \frac{L_{ref}}{D_{ref}} \cdot \frac{V_{ref}^2}{2g} ; Re = \frac{V_{ref} \cdot D_{ref}}{\nu} = \frac{2 \cdot 0,3968}{8,6655 \cdot 10^{-7}} = 915815,5906 > 2300$$

So the regime is turbulent rough

The value of the linear pressure loss coefficient will be:

$$\lambda = 0,0032 + 0,221 \cdot Re^{-0,237} = 0,0032 + 0,221 \cdot (915815,5906)^{-0,237} = 0,0117$$

$$\Delta h_{linref} = \lambda \cdot \frac{L_{ref} \cdot V_{ref}^2}{D_{ref} \cdot 2g} = 0,0117 \cdot \frac{850}{0,3968} \cdot \frac{2^2}{2 \cdot 10} = 5,0126 \text{ m}$$

Singular pressure drops

They are given by the formula below:

$$h_{sing} = n \cdot k \cdot \frac{v^2}{2g}$$

Our circuit (Section 2) includes:

- 7 bends including: 6 bends of 90°; 1 elbow of 60°
- 1 check valve
- 2 valves
- 1 strainer

Then the singular head losses are worth:

for a check valve

$$(k=1): = 0.2\text{m}$$

for 2 valves (k=1.5)

$$: = 2 \cdot 1.5 \cdot = 0.6\text{m}$$

for a strainer (K=1)

$$: = 0.2\text{m}$$

for 6 bends of 90° (k=1.2): = 6 \cdot 1.2 \cdot = 1.44\text{m}

for 1 elbow of 60° (k=0.60): = 1 \cdot 0.60 \cdot = 0.12\text{m}

++++

$$= 0.2 + 0.6 + 0.2 + 1.44 + 0.12 = 2.56\text{m}$$

So the total losses are:

$$= + + = 0.0275 + 5.0126 + 2.56 = 7.6\text{m}$$

d) Determination of the manometric head

$$= + = 355 + 7.6001 = 362.6\text{m}$$

e) Choice of pumps

The choice of pumps for this section is also conditioned by the flow maximum and the manometric height.

The pump to be chosen must have a flow greater than 890 m³/h and a head greater than 362.60 m.

Based on these results, we choose the FLOWSERVE 201 NM pump which has a nominal flow rate of 450 /h and a head of 400 m.

We will take

2 FLOWSERVE 201 NM pumps which will be put in parallel (24/24) - 1 reserve pump of the same type.

f) Determination of operating point 2

$$H = H_g + h \left(\frac{Q_i}{Q_{tot}} \right)^2 \text{ Avec } Q_{tot} = 450 \times 2 = 900 \text{ m}^3/\text{h}$$

Table III.11: Calculation of head losses at different flow rates for section 2

Qi	Hg	h	Qtot	Hm
0	355	7.6001	900	355
30	355	7.6001	900	355.008445
60	355	7.6001	900	355.033778
90	355	7.6001	900	355.076001
120	355	7.6001	900	355.135113
150	355	7.6001	900	355.211114
180	355	7.6001	900	355.304004
210	355	7.6001	900	355.413783
240	355	7.6001	900	355.540452
270	355	7.6001	900	355.684009
300	355	7.6001	900	355.844456
330	355	7.6001	900	356.021791
360	355	7.6001	900	356.216016
390	355	7.6001	900	356.42713
420	355	7.6001	900	356.655133
450	355	7.6001	900	356.900025
480	355	7.6001	900	357.161806
510	355	7.6001	900	357.440477
540	355	7.6001	900	357.736036
570	355	7.6001	900	358.048485
600	355	7.6001	900	358.377822
630	355	7.6001	900	358.724049
660	355	7.6001	900	359.087165
690	355	7.6001	900	359.46717
720	355	7.6001	900	359.864064
750	355	7.6001	900	360.277847
780	355	7.6001	900	360.70852
810	355	7.6001	900	361.156081
840	355	7.6001	900	361.620532
870	355	7.6001	900	362.101871
900	355	7.6001	900	362.6001

The figure below gives us the curves of the flows according to the manometric heads of network 2 (in red), of the pump (in blue) and of the pumps placed in parallel (in green).




Figure 3: Operating point of section pumps

Thus we obtain our operating point of a pump at (280; 355) and pumps placed in parallel at (550; 360) in the figure above.

1.3 Relay Station Design. (GEOFFREY, 2012)

A relay station on level 355 will allow us to retain solid particle-laden water from the 505 level of Zone 5 of the Kamoto underground mine. This station will allow the decantation of these solid particles by improving the quality of the water and the pumping at level 355.

These particles will accumulate at the bottom of the basin, from where they will be extracted periodically by cleaning. The water collected on the surface is said to be clarified and will then be pumped to the upper levels.

In the design of a settling pond (decanter) in a mine underground, we opt for the rectangular longitudinal shape




Figure III.4: Shape of an ideal

We have as data:

- The water temperature: $T^{\circ} \text{ water} = 20^{\circ} \text{ C}$
- The density of water: $= 1.154. \text{ Kg/}$
- Density of solids: $= 2600 \text{ Kg/}$
- The acceleration of gravity: $g=10 \text{ m/}$

The decanter must be such that at least the 10 μm particles of diameter are retained. Indeed, according to the manufacturer of FLOWSERVE pumps, water becomes abrasive when its suspended solids content exceeds 10 mg/l with a diameter of 10 μm .

Moreover, such a particle is retained if and only if the time of settling is less than the residence time. ($T_d < T_s$) with:

We get the following relationship: (III.12)

With:

- h: the height of the decanter (m)
- v: the limit speed of fall of solid particles (m/s)
- L: length of the decanter (m)
- v: fluid velocity (m/s)

a) Settling time (td)

The limit speed of fall of the particle is given by the following relation:

$$(m/s) \text{ (III.13)}$$

With :

- g: acceleration due to gravity (m/)
- ρ : density of solids (kg/)

because it has a technical simplicity that requires little maintenance and unskilled labor.

In an underground mine, the construction of a settling basin requires that the surrounding rock be of good resistance and impermeable so that the settling can take place in good conditions. Otherwise, we are forced to project the concrete to make the rock waterproof.

For it to have decantation of the particles in suspension in the water, it

The falling speed of the particles should be greater than the horizontal speed of the water in the basin, in other words the time required for the particles to settle to reach the bottom should be less than the time required for the liquid to cross the settler horizontally.

1.3.1. Sizing of the decanter

The decanter will have an ideal rectangular shape below:

Legend

- A_s :the lateral ground surface of the decant, (m^2)
- S_T :the cross-sectional area of the decanter (m^2)
- S_L :the longitudinal surface of the decanter (m^2)
- L :the length of the decanter (m)
- l :the width of the decanter (m)
- h :the height of the decanter (m)

- ρ : density of Kamoto water (kg/)
- μ : the dynamic viscosity of water (Pa.s) The limiting speed of fall is then: m/s

Since the efficiency of a decanter does not depend on the depth, so we assumed that the height is 1 m

So the settling time is:

$$T_d = \frac{h}{v_L} = \frac{1}{8,017298736.10^{-5}} = 12448,13278 \text{ s} = 3 \text{ hours } 30 \text{ mins}$$

b) Residence time (Ts)

The lateral ground surface of the decanter A_s is given by the relation below [MAPAQ, 1990]:

$$A_s = \phi. \text{ (III.13)}$$

With :

- ϕ : the adjustment factor linked to the turbulence. For security reasons we take 1.5

$$\text{So } A_s = 1.5. = 4625.4149$$

In general for a rectangular decanter, the ratio of the width (l) over length (L) is 1/6. (ENSEE, 2012):

$$\text{Hence } \rightarrow L = 6.l \text{ (III.14)}$$

$$\text{Or } A_s = L. l = 6. \rightarrow l = m$$

$$\text{Then } L = 6.l = 6. 27.7651 = 166.59 \text{ m}$$

$$T_s = \text{hours } 12 \text{ min}$$

This satisfies the settling condition.

A decanter having enormous dimensions would entail a high cost of digging and stability problems (its support would be very expensive). To remedy this problem, we resort to the use of flocculants which allow us to accelerate the decantation (the decantation speed) and thus reduce the dimensions of the decanter.

c) Sizing decanter with a flocculant

The flocculant used is an anionic flocculant (GELBOCK 5H4/Y26/S/ZA/TE 7222) which is white in color, a concentration of 4 g/l, a dilution rate of 10 and is in the form of solid grains.

In order to speed up the settling time, we did a test to see how this flocculant will behave and thus determine the settling rate.

Settling test

Materials used

- The 1000 ml stemmed glass;
- 125 ml bottles;
- Filter papers for solids;
- Mechanical stirrer;
- A wash bottle;
- An electronic scale;
- An oven; - A stopwatch;
- A separatory funnel.

Operating mode

- Take 650ml of water containing solid particles in suspension and place it in the graduated burette
- Take 2.8g of solid flocculant and mix it with 50ml of clear water;
- Gradually pour the flocculant solution into the burette containing water with the solids in suspension
- Time the time for the water to clear.
- Withdraw 100 ml of the clear solution for the determination of the quantity of solids remaining;
- filter the sample to retain solids;
- Place the previously weighed filter paper in an oven heated to 100°C for 45 minutes;
- Determine the quantity of solids retained on filter paper by weight difference.
- Repeat this procedure for 0; 1; 2; 3; 4; 5 minutes

Presentation of the results

The tests were carried out with a volume of 700 ml of water with a dose of flocculant of 4g/l.

- For $t = 0$ min, we have a solid content of 462 g/l
- For $t = 1$ min, the solid content is 123 g/l
- For $t = 2$ min, the content becomes 10 g/l
- For $t = 3$ min, the solid content is 8 g/l

For $t = 4$ min, it is 8g/l

For $t = 5$ min, the solid content is 7 g/l

Looking at the results of our settling tests, we find that after 2 minutes, there is already almost 10 g/l of solid content remaining, therefore 452 g/l of solid eliminated, which makes approximately 97% of the settled solids. The tests were carried out with 700 ml of water using a 1000 ml

burette measuring 150 mm in height; which gives a water column of 105 mm. And since settling already occurs after 2 min, the settling rate using this flocculant is equal to:
 $= 0.000875$ m/s

The side surface of the decanter becomes:

$A_{ce} =$

The width of the decanter and the length are respectively:

$l = m$ and $L = 6.84 \cong 50$ m

1.4 Decanter cleaning

The cleaning of the decanters is done using mud pumps. For the Kamoto underground mine, we will use BRAVO type mud pumps.

The cleaning of the decanter (the relay station) must meet certain underground mine requirements.

To facilitate cleaning, we suggest compartmentalising the decanter as shown in the figure below:




Figure 3: 5 Lateral section of the decanter

Decanter presentation

- The decanter is subdivided into 5 compartments
- Compartment 5 represents the outfit where the suction pipes will be placed, which will be used to discharge clear water to the upper levels
- Compartments 1 and 2 will receive water from lower levels
- The first settling is done in 1 and 2; then the second will be done in 3 and 4 to finally have clear water in compartment 5;
- Between compartments 1 and 3 and 3 and 5 there will be a small passage of water to 3 and from 3 to 5 which will be placed in a staircase to prevent a reversal of the water already decanted in the rear compartments. We will do the same between 2 to 4 and from 4 to 5.

Cleaning procedure

To avoid the stoppage of all pump installations (pumps and motors) at the time of cleaning, the cleaning is planned as follows:

→ Cleaning of part 1 (Compartment 1 and 3)

- Pump the water back into compartments 1 and 2;
- Isolate the first part to be cleaned consisting of compartments 1 and 3 by stopping valve 1 and leaving valve 2 open;
- Place a FLYGT pump in compartment 1 then 3;
- Pump the water from two compartments (1 and 3) until it reaches the sludge level;
- Remove the FLYGT pumps;
- Place the discharge pipe and install the BRAVO mud pump on a monorail previously placed during the installation of the decanter used to slide the cleaning mud pump towards compartments 1 and 3;
- Connect the mud pump to the delivery pipe;
- Spray the working water and start pumping until the decanter compartment is emptied;
- Free compartments 1 and 3 by removing all cleaning equipment and open valve 1.
- Cleaning of part 2 (Compartment 2 and 4)
- Isolate the second part by closing valve 2;
- Move the cleaning equipment to the side of the second part;
- Pump the water from 2 and 4 until it reaches the mud using the FLYGT pumps;
- Move the discharge pipe to compartments 2 and 4;
- Install the BRAVO mud pump, always using the monorails which will be used to slide the mud pump towards 2 and 4;
- Connect the mud pump to the delivery pipes;
- Spray the working water and start pumping the sludge until compartments 2 and 4 are emptied;
- Release compartments 2 and 4; - Open valve 2.

2. Conclusion

The 505-surface dewatering project in the KAMOTO mine allowed us to quantify all the water inflows to zone 5 in order to allow us to properly size our dewatering circuit. The maximum influx to zone 5 being well determined, this allowed us to properly size the circuit; this circuit is divided into two sections. This leads us for the first section to choose 4 Flowserve pumps of the 150 NM type, which has a nominal flow rate of 250 m³/h and a manometric head of 250 m, which will be installed in parallel and 1 spare pump of the same type. As for the second section, we choose 2 Flowserve type 201 NM pumps with a nominal flow rate of 450 m³/h with a head of 400 m which will be placed in parallel and 1 pump of the same type in reserve. And after sizing the decanter with flocculant, we obtained The following results: the lateral surface of the decanter is 423.81; the width 8 m and the length 50 m.

To make it easier for the decanter to be cleaned at the same moment the water was pumped, the decanter was split into compartments; therefore the cleaning will take place without stopping the dewatering pumps. It will be done using BRAVO 400 type mud pumps.

References

- [1] Berthelot 1930: BERTHELOT (Ch.). — Minerals; study, mechanical preparation, market, Paris, Mining and Metal Encyclopedia.
- [2] Buckley 2002: BUCKLEY (J.A.). — Cornish Mining at surface. Tor Mark presses Penryn. 32 p.
- [3] Burt and Waite 1988: BURT (R.) and WAITE (P.). — Bihliography of the History of British Metal Mining. University of Exeter. A. Wheaton and Co. Ltd., Exeter. 177 p.
- [4] Cupillard 1991: CUPILLARD (Ch.). — The Blanc-Saule mining site at Etrelles-la-Montbleuse. Flint at ground level. The exploitation of the raw material in the region of Etrelles (Haute-Saône), Pub. CRDA Besançon, p. 70.
- [5] Hesse 1968: HESSE (P.J.). — The mine and miners in France from 1300 to 1550, Paris, State Doctorate Thesis, University of Paris, 3 vol., 815 p.