

agricultural environment for social modernization of Indian agricultural system.

The lighting control system for energy savings in current markets can support on-off and dimming control as managing lighting devices after detecting an object or intensity of illumination, or controlling with time setting. Furthermore, although most existing systems have variable control parameters, it is difficult for users to modify these parameters, so that it is not appropriate to be applied in various places. In addition, although the lighting control system using central management server or sensor networks was studied recently, it was not commercialized or industrialized, and even the commercialized products were excessively concentrated to the central management server.

2. System Design Model

This paper proposes an intelligent household LED lighting system considering energy efficiency and user satisfaction. The proposed system utilizes multi sensors and wireless communication technology in order to control an LED light according to the user's state and the surroundings. The proposed LED lighting system can autonomously adjust the minimum light intensity value to enhance both energy efficiency and user satisfaction.

A. Hardware Section

The prototype and hardware block diagram of the proposed system. The main processor part uses 32-bit microprocessor. This part plays a role in situation analysis, event processing, and learning. This part optimizes the control and state variables to adapt itself to the various environments. The sensor part is composed of various sensors. To provide energy saving services mentioned above, two kinds of sensors, that is a motion detection sensor and illumination sensor are needed basically. A ZigBee (250 kbps/2.4 GHz) module is used for communication with other LED lighting system and networked devices. LED driver part consists of current controller modules for driving LEDs. There are two ports that are controllable and are able to control for 255 levels of brightness. The power part is composed of a power regulator and SMPS.




Figure 1: Overview of the proposed system

The proposed system basically controls illumination intensity of a lighting device according to user movement and brightness of surroundings. That is, when the maximum value of illumination intensity of a lighting device is L_{max} and the minimum value is L_{min} , the illumination intensity becomes L_{max} , if user movement is detected and becomes L_{min} , if user movement is not detected for certain period time. There are many people in a home and office building; thus, user satisfaction is an important factor in the light evaluation. In these places, L_{min} is set according to the proposed minimum light intensity control algorithm. Generally, L_{min} is set to the high value in these places.

B. Software Section

This is an Operating System (OS) on which all the software applications required for our design are going to be run. This OS is flexible to any user to operate and easy to understand. Accessing the soft wares and using them is very convenient to user. Or-CAD is a proprietary software tool suite used primarily for electronic design automation. The software is used mainly to create electronic prints for manufacturing of printed circuit boards, by electronic design engineers and electronic technicians, to manufacture electronic schematics. The μ Vision development platform is easy-to-use and it helps you quickly create embedded programs that work. The μ Vision IDE (Integrated Development Environment) from Keil combines design management, source code editing, program debugging, and complete simulation in one powerful environment. Code written in 'EMBEDDED C'.




Figure 2: schematic design of the experiment by using ORCAD

The μ Vision3 IDE is a Windows-based software development platform that combines a robust editor, design manager, and makes facility. μ Vision3 integrates all tools including the C compiler, macro assembler, linker/locator, and HEX file generator.

3. Experimental Results

It is the module to possess the core function of the adaptive middleware. Basically, it is mainly used for the manager management, scheduling for managers, and access control of the table used by the managers. It registers and activates the managers upon receiving the control messages from the external management server. It also performs the role of deleting the existing managers in accordance with the commands transferred from the management server. In addition, it performs the role related to authentication for external management server. This group can registers and deletes the managers in the adaptive middleware group in real time. The illumination sensor manager performs the roles of gathering the value of intensity of illumination from the sensor or making the rule table for control upon receiving the data sensed from the sensor module, the neighboring lighting system, or the management server.




Figure 3: Experimental Kit

Intelligent wireless monitoring household LED lighting system considering different modules like LDR, LCD, microcontroller, IR sensors, LED lights etc.




Figure 4: Detect the object

The IR sensor detects which number of persons entering in the room or hall. Sending to the information to microcontroller. The person no is 0 then the LED lights are not glow. Room or hall exit side IR sensor detect the which number of persons are decrease in the room. Persons are decrease up to 5 persons then the second LED light is off only one LED light is on. Persons are decrease up to zero persons the LED lights are off state. Temperature sensor detects the temperature. The normal room temperature is 29 to 30 degrees. The room temperature increases up to 40 degrees then the temperature sensor detect the temperature then the ac or fans are automatically on. Room temperature decrease slowly up to 29 to 30 degrees automatically ac or fans are off.




Figure 5: Hyper Terminal Window

In the windowsxpversion .Click start next –click programs–click accessories–click communication–click hyper terminal–click ok. In the hiper terminal window giving the name and save the name. Next connect to windows in that windows connect wire com1–click ok.

4. Conclusion

Light accounts for approximately 20 percent of the world's total energy consumption; thus, a lot of studies and development related to energy saving of a light have been done by various researchers all over the world. However, since there are no products considering both energy efficiency and user satisfaction, the existing systems cannot be successfully applied to home and office buildings. Therefore, we propose an intelligent household LED lighting system considering energy efficiency and user satisfaction. The proposed system utilizes multi sensors and wireless communication technology in order to control an LED light according to the user's state and the surroundings. The proposed system can autonomously adjust the minimum light intensity value to enhance both energy efficiency and user satisfaction. We designed and implemented the proposed system in the test bed and measured total power consumption.


References

- [1] S. Tompros, N. Mouratidis, M. Draaijer, A. Foglar, and H. Hrasnica, "Enabling applicability of energy saving applications on the appliances of the home environment," *IEEE Network*, vol. 23, no. 6, pp. 8-16, Nov.- Dec. 2009.
- [2] Tao Chen, Yang Yang, Honggang Zhang, Haesik Kim, and K. Horneman, "Network energy saving technologies for green wireless access networks," *IEEE Wireless Communications*, vol. 18, no. 5, pp. 30-38, Oct. 2011.
- [3] J. Byun and S. Park, "Development of a self-adapting intelligent system for building energy saving and context-aware smart services," *IEEE Trans. on Consumer Electron.*, vol. 57, no. 1, pp. 90-98, Feb. 2011.
- [4] J. Han, C.-S. Choi, and I. Lee, "More efficient home energy management system based on ZigBee communication and infrared remote controls," *IEEE Trans. on Consumer Electron.*, vol. 57, no. 1, pp. 85-89, Feb. 2011.
- [5] Ç. Atıcı, T. Özçelebi, and J. J. Lukkien, "Exploring user-centered intelligent road lighting design: a road map and future research directions," *IEEE Trans. on Consumer Electron.*, vol. 57, no. 2, pp. 788- 793, May 2011.
- [6] A. A. Siddiqui, A. W. Ahmad, H. K. Yang, and C. Lee, "ZigBee based energy efficient outdoor lighting control system," in *Proceedings of the International Conference on Advanced Communication Technology*, pp. 916-919, 2012.
- [7] M.-S. Pan, L.-W. Yeh, Y.-A. Chen, Y.-H. Lin, and Y.-C. Tseng, "A WSN-Based Intelligent Light Control System Considering User Activities and Profiles," *IEEE Sensors Journal*, vol. 8, no. 10, pp. 1710- 1721, Oct. 2008.
- [8] Y. Uhm, I. Hong, G. Kim, B. Lee, and S. Park, "Design and implementation of power-aware LED light enabler with location-aware adaptive middleware and context-aware user pattern," *IEEE Trans. On Consumer Electron.*, vol. 56, no. 1, pp. 231-239, Feb. 2010.
- [9] T.-J. Park and S.-H. Hong, "Experimental Case Study of a BACnet- Based Lighting Control System," *IEEE Trans. on Automation Science and Engineering*, vol. 6, no. 2, pp. 322-333, Apr. 2009.
- [10] S. Matta and S. M. Mahmud, "An intelligent light control system for power saving," in *Proceedings of the Annual Conference of the IEEE Industrial Electronics Society*, pp. 3316-3321, 2010.
- [11] F. J. Bellido-Outeirino, J. M. Flores-Arias, F. Domingo-Perez, A. Gil-de- Castro, and A. Moreno-Munoz, "Building lighting automation through the integration of DALI with wireless sensor networks," *IEEE Trans. On Consumer Electron.*, vol. 58, no. 1, pp. 47-52, Feb. 2012.
- [12] F. Leccese, "Remote-Control System of High Efficiency and Intelligent Street Lighting Using a ZigBee Network of Devices and Sensors," *IEEE Trans. on Power Delivery*, vol. 28, no. 1, pp. 21-28, Jan. 2013.
- [13] D. T. Delaney, G. M. P. O'Hare, and A. G. Ruzzelli, "Evaluation of energy-efficiency in lighting systems using sensor networks," in *Proceedings of the First ACM Workshop on Embedded Sensing Systems for Energy-Efficiency in Buildings*, pp. 61-66, 2009
- [14] G. W. Denardin, C. H. Barriquello, R. A. Pinto, M. F. Silva, A. Campos, and R. N. do Prado, "An Intelligent System for Street Lighting Control and Measurement," in *Proceedings of the IEEE Industry Applications Society Annual Meeting*, pp. 1-5, 2009.

Author Profile



K. Sampath, Pursuing M.Tech Embedded Systems Dept. Of ECE In Jyothishmathi Institute Technology & Science, Nustullapur, Karimnagar -District, A.P, INDIA. I Have Completed B.Tech From Sree Chaitanya Engineering College At Karimnagar. I Have Attended 2 National Workshops And I Have Given 1 Paper Presentation In Nation Level.



S. China Venkateswarlu, Research Scholar from JNTUK, Kakinada. IEEE Member, B.Tech, M.Tech, MISTE, CSI, IAENG, working as a Professor & HOD in Dept. Of ECE from Jyothishmathi Institute Technology & Science, Nustullapur, Karimnagar -District, A.P, INDIA, Worked in various Engineering College and have 16 years of Teaching and R&D experience. Currently doing research in the area of Digital Signal Processing / Speech Processing. He has presented 13 National, 12 International Conference Papers are Presented through EDAs. He has published 32 research papers in National and International Journals. Research interest in Signal Processing, Speech Processing, Wireless Communications and Embedded Systems. He is currently pursuing PhD from JNTU Kakinada. He has reviewed more than 24 research papers.