Design for Thermal Comfort during Summer & Psychometry Tool for Human Comfort

Syed Faheem¹, Syed Mujeeb Ali², Syed Suleman³, Syed Obaid Ur Rahman⁴, Syed Wali Uddin Irfan⁵

B. Tech final year, Dept. of Mechanical Engineering, Jawaharlal Nehru Technological University, Lords Institute of Engineering and Technology, Himayathsagar, Hyd T.S-500008, India

Guide and Asst. Professor S M Azfar Hashmi,

Asst. Professor Chanduri Rajendra Prasad, Dept. of Mechanical Engineering, Jawaharlal Nehru Technological University, Lords Institute of Engineering and Technology, Himayathsagar, Hyd T.S-500008, India

Abstract: Central Air Conditioning is more reliable for easy operation with a lower maintenance cost. The effective design of central air conditioning can provide lower power consumption, capital cost and improve aesthetics of a building. This paper establishes the result of heating load calculation under different climatic conditions by using E-20 for a multi-story building. Heating load items such as people heat gain, lighting heat gain, infiltration and ventilation heat gain and cooling load due to walls and roofs. Using ISHRAE and CARRIER fundamental hand books and here the study of air water vapor mixture (called psychometric) for human comfort in the air conditioning system for the city Hyderabad.

Keyword: Temperature difference, thermal resistance, overall heat transfer coefficient, E-20 performa, ISHRAE Std.

1. Introduction

Heating, ventilation and air conditioning (HVAC) is the technology of indoor and vehicular environmental comfort. Its goal is to provide thermal comfort and acceptable indoor air quality. HVAC system design is a sub discipline of mechanical engineering, based on the principles of thermodynamics, fluid mechanics, and heat transfer. Refrigeration is sometimes added to the field's abbreviation as HVAC&R or HVACR, or ventilating is dropped as in HACR.

Energy efficiency can be improved more by installing central heating systems which allows more granular application of heat. Zones can be controlled by multiple thermostats. The HVAC industry is a worldwide enterprise, with roles including operation and maintenance, system design and construction, equipment manufacturing and sales, and in education and research. The HVAC industry was historically regulated by the manufacturers of HVAC equipment, but regulating and standards organizations such as *HARDI, ASHRAE, SMACNA, ACCA*, Uniform

Mechanical Code, International Mechanical Code, and *AMCA* have been established to support the industry and encourage high standards and achievement.

The starting point in carrying out an estimate both for cooling and heating depends on the exterior climate and interior specified conditions. However, before taking up the heat load calculation, it is necessary to find fresh air requirements for each area in detail, as pressurization is a building environment standards. It establishes the general principles of building environment design. It considers the need to provide a healthy indoor environment for the occupants as well as the need to protect the environment for future generations and promote collaboration among the various parties involved in building environmental design sustainability. ISO16813 is applicable to new for construction and the retrofit of existing buildings.

The building environmental design standard aims to:

- Provide the constraints concerning sustainability issues from the initial stage of the design process, with building and plant life cycle to be considered together with owning and operating costs from the beginning of the design process.
- Assess the proposed design with rational criteria for indoor air quality, thermal comfort, acoustical comfort, visual comfort, energy efficiency and HVAC system controls at every stage of the design process;
- Iterate decisions and evaluations of the design throughout the design process.

2. Methodology

- Commercial building plan of 11634.5 square feet
- Calculation of floor, roof, wall and windows areas.
- Calculation of temperature difference (ΔT).
- Thermal resistance of wall, roof and windows.
- E-20 ISHRAE Std.
- Overall heat transfer co efficient.
- Heating load in BTUH.

3. Psychometric condition during summer in Hyderabad

Dry Bulb Temperature- 105°F Relative Humidity-70-80%

As the above conditions for the citizens of Hyderabad is not comfortable. So, the air should be dehumidified and should bring the temperature at 72° F- 76° F, and relative humidity to 50%-60%. For this cooling is required in a space.

International Journal of Science and Research (IJSR) ISSN (Online): 2319-7064 Index Copernicus Value (2015): 78.96 | Impact Factor (2015): 6.391



4. Design

For estimating cooling loads, one must consider the unsteady state processes, as the peak cooling load occurs during the day time and the outside conditions also vary significantly throughout the day due to solar radiation. In addition, all internal sources add on to the cooling loads and neglecting them would lead to underestimation of the required cooling capacity and the possibility of not being able to maintain the required indoor conditions. Thus, cooling load calculations are inherently more complicated as it involves solving unsteady equations with unsteady boundary conditions and internal heat sources.

1) Cooling load calculation

(heat load calculation i.e. heat gain through all the sources)

- Application for summer
- Process is directly to cooling and dehumidification (required in wet summer)
- Cooling and humidification (required in dry summer like in desert areas where there is no water available for evaporation).

Definition: The room cooling load is a rate at which the heat must be removed from the room air in order to maintain it at desired temperature and humidity.

2) Sources of heat (Q_{in})

a) External sources

- Heat gain through glass due to conduction
- Heat gain through glass due to radiation
- Heat gain through skylight (conduction & radiation)
- Heat gain through wall (sensible)
- Heat gain through roof (sensible)
- Heat gain through partition, floor and ceiling due to conduction (sensible heat)
- Heat gain through ventilation due to convection (sensible & latent heat)
- Heat gain through infiltration due to convection (sensible & latent heat)

b) Internal sources

- Heat gain through lighting (sensible heat)
- Heat gain through people (sensible and latent heat)
- Heat gain through appliances

- 1) Business appliances printer , computer, scanner etc
- 2) Kitchen appliances rice cooker, coffee maker etc

c) City Temperature:-

Total number of hours in a year : 8760 hours For 0.4% : 35 hours ~ 1.5 days/ year DB: 76 F, MWB : 63 F is comfort level for Hyderabad city

3) Finding 'U' Value

U=Overall coefficient of heat transfer in BTU/(hr-sft-F) R=Thermal resistance of material (R>U)

 $U=1/\Sigma R$

Where, $\sum R = Ri + X1R1 + X2R2 + X3R3 + \dots + XnRn + Ro$ Ri = Resistance of inside air film = 0.68 (std value) Ro = Resistance of outside air film = 0.25 for summer @ 7.5 m/s wind velocity

Ro = 0.17 for winter @ 15 m/s wind velocity

Ra = Resistance of air film gap = 0.91

Note:

- 1) Ro may vary as per location
- 2) Ra is standard value irrespective of thickness of the air gap.
- 3) R1,R2,R3...Rn is the resistance of the material
- 4) X= thickness of material
- 5) value of R for different material are taken from resistance table of data book.

4) 'U' Value of Buildinga) 9" COMMON WALL:



- $\sum R = R_0 + X_1 R_1 + X_2 R_2 + X_3 R_3 + R_i$ = 0.25+(0.5x0.12)+(8x0.2)+(0.5x0.12)+0.68 = 2.65
- U = $1/\Sigma R = 1/2.65 = 0.37 \text{ Btu/(hr-ft^2-F)}$

b) 0.25" GLASS:-

Volume 6 Issue 2, February 2017 www.iisr.net

Licensed Under Creative Commons Attribution CC BY



- **3)** Roof Area : $18'-6'' \ge 20' = 370 \text{ Ft}^2$
- Heat Gain Through External Sources

1. Heat Gain through Glass

a. Through Conduction :

Q=UxAx∆T

For Hyderabad, midday is found at 2pm. Therefore, the timing = 2+2 = 4pm

• Equivalent temperature requirements : 1) Weight or thickness of the wall :100 lb/sft or 9"

2) Timing : midday + 2 hours(storage effect)

 $\Delta T = Equivalent temperature + correction factor$

Volume 6 Issue 2, February 2017

www.ijsr.net

Licensed Under Creative Commons Attribution CC BY

Using above parameter,

From [Data book, table – 19]

We get, Equivalent temperature = 16 F

• Correction factor requirements :

1) Range = Maximum outside DB – Minimum outside DB = 10.5°C (from ASHRAE Climatic Data Software) shown below $= 18.9^{\circ}F \sim 19^{\circ}F$

2) Temperature Difference = $T_0 - T_i$ = 105 - 76 $= 29^{\circ}F$

Using above parameters, From [Data Book, Table – 20A] We get,

Correction factor = 14FTherefore, $\Delta T = 16+14 = 30$ F As a result,

Q=0.37 x 156 x 30 = 1731.6 Btu/hr

b) FOR WEST WALL

 $U = 0.37 \text{ Btu/hr-ft}^2\text{-F}$ $A = 120 \text{ ft}^2$ $\Delta T = Equivalent temperature + Correction factor$ = 12 + 14 = 26 F

Thus,

Q=0.37 x 120 x 26=1154.4Btu/hr

• Heat Gain Through Roof Thickness of the roof = 6"

Q=U x A x ∆T Btu/hr

Where,

Online $U = 0.1 Btu/hr-ft^2-F$ $A = 370 \text{ ft}^2$ $\Delta T = Equivalent temperature + correction factor$ (Correction factor = 14)

• Equivalent temperature requirements :

1) Weight of the roof: 40 lb/sft 2) Timing: midday + 2 hours 2pm + 2 = 4pm

Using above parameters, we get, from [Data Book, table -20] we get, Equivalent temperature = 38 F $\Delta T = Equivalent temperature + correction factor$ $\Delta T = 38 + 14 = 52 F$ Thus,

Q = 0.1 x 370 x 52 = 1924 Btu/hr

Heat Gain Through Ventilation

1. Sensible Heat Gain :

Q_s=1.08 x CFM x △T Btu/hr

Where.

NWW.II

1.08 = specific heat of air

CFM = Ventilation flow rate in cubic feet per minute $\Delta T = T_o - T_i = 105 - 76 = 29 \text{ F}$

To find CFM we use two methods

- 1) Person method
- 2) Area method

• Person method : CFM = number of people x CFM per person [Data Book, Table – 45] we get, CFM per person = 25Therefore according to the people method CFM = 7 x 25 = 175

 Area method: CFM = Floor area x CFM per sq.ft [Data Book, Table -45] from above table, we get, CFM per sq.ft = 0.25There according to the area method CFM = 370 x 0.25 = 92.5

We should select the maximum value among two.

$$Q_{z} = 1.08 \times 175 \times 29 = 5481$$

2. Latent heat gain:

$$Q_L = 0.68 \text{ x CFM x } \Delta W \text{ Btu/hr}$$

Where. 0.68 = specific heat of moister CFM = 175 $\Delta W = W_o - W_i =$ Humidity Ratio Now considering the psychometric chart, we have the following details, DB = 105 F & WB = 72 F Therefore, $W_0 = 65 \text{ gain/lb}$ And also, DB = 76 F and RH = 50% which provides the details for $W_i = 67$ gain/lb

Therefore, $Q_L = 0.68 \text{ x CFM x } (W_o - W_i)$

Q_L = 0.68 x 175 x (-2) = -238 Btu/hr

Note : the -ve sign indicates loss in latent heat because of decrease in humidity.

• Heat Gain Through Infiltration

The infiltration occurs when the outside air enters through the opening due to the wind pressure. Infiltration of air through crack around windows and through area from doors results in both sensible and latent heat gained to rooms.

1. Sensible heat gain :

Q_s=1.08 x CFM x ∆T Btu/hr

• Crack Method to find CFM for infiltration

The crack method assumes that a reasonably accurate estimate of the rate of infiltration perfect of crack opening.

• For windows

CFM = crack in ft(Perimeter) x CFM/ft Where perimeter of glass = (6x2)+(12x2)+(9x2)+(12x2) = 78 ft CFM = 78 x 0.37 = 28.86

• For doors

 $CFM = crack in ft^2(Area) \times CFM/ft^2$ Since there is no exposed door in this space so door CFM would not be considered, if there is door CFM then total CFM will be sum of the windows and doors CFM. now the total CFM is

CFM=78 x 0.37 = 28.86

Q_s=1.08 x 28.86 x 29 = 903.86 Btu/hr

2. Latent Heat Gain :

 $Q_L = 0.68 \text{ x CFM x } \Delta W \text{ Btu/hr}$

 $Q_L = 0.68 \ge 28.86 \ge (-2) = -39.24 \text{ Btu/hr}$

• Heat Gain Through Internal Sources

1) Heat Gain Through Lighting :

 $Q = W \times B.F \times 3.4 \text{ Btu/hr}$ Where, W = Wattage B.F = ballast factor 1 W= 3.4 Bt/hr

Ballast factor depends on the type of light, since we are using fluorescent light so the ballast factor is 1.25. Using the thumb rule, for office application, we have W = 2 x floor area = 2 x 370 = 740 watts

As a result,

Q = 740 x 1.25 x 3.4 = 3145 Btu/hr

2) Heat Gain Through People :

• Sensible Heat Gain:

Q₅= q₅ x n Btu/hr

Where,

 Q_s = Total sensible heat gain q_s = sensible heat gain per person n = number of people = 7 [Data Book, Table - 48]

From the above, for office worker at room temperature 75 F, $q_s = 245$ Btu/hr therefore,

Q_s= 245 x 7 = 1715 Btu/hr

• Latent Heat Gain :

$Q_L = q_l x n Btu/hr$

```
=205 \text{ x } 7 \text{ Btu/hr}
```

Q _L = 205 x 7 = 1435 Btu/hr	
Ista	

Note:

- The rate of heat gained from people depends upon the physical activity.
- As the physical activity increases, the latent heat increases when compare with sensible heat.

3) Heat Gain Through Appliances

Q = W x 3.4 Btu hr Where, W = Wattage WATTAGE PER APPLIANCE:

1. Wattage for computer

Number of computer : 5 CPU : 49 Watts Monitor : 28 Watts Total : 49 + 28 = 77 watts Therefore, as per requirement, 5 x 77 = 385 watts

2. Wattage for printer

Number of printer : 01 Wattage : 130 watts Therefore, as per requirement, 1 x 130 = 130 watts.

Total Wattage Acquired = 385 + 130 = 515 Watts.

Heat gain through appliances: $Q = W \times 3.4 Btu/hr$

Q=515 x 3.4 = 1751 Btu/hr

S.No	Sources	Sensible heat gain	Latent heat gain			
		(Btu/hr)	(Btu/hr)			
01	Glass	18091				
02	Walls	2886				
03	Roof	1924				
04	Ventilation	5481	-238			
05	Infiltration	904	-39			
06	Lighting	3145				
07	People	1715	1407			
08	Appliances	1751				
09	Sub Total	35897	1130			
10	Safety factor	10% = 3589.7	5% = 56.5			
11	Total	39487	1187			

Volume 6 Issue 2, February 2017 www.ijsr.net

hline

Licensed Under Creative Commons Attribution CC BY

Grand Total = total sensible heat gained + total latent heat gained

= 39487 + 1187 = 40674 Btu/hr 12000 Btu/hr = 1 T.R Therefore, Ton of refrigeration = 40674/12000 = 3.3 ~ 3.5 T.R

= 40674 Btu/hr

• Converting Btu/hr into ton of refrigeration (T.R)

PERFORMA OF E-20 OF A SPACE												
	•	•		COOL	ING LOA	D CAI	LCULA	TIONS	•	·	·	
					20 N	LATITU	ТЕ	0	0			
PROJECT DETAILS					DESIGN CONDITIONS - HYDERABAD							
Project Name:	MINI P	ROJECT	Date:					DBT(F)	WBT(F)		RH(%)	HR (Gr/lb)
Space:		ROOM	M : 101		Outdoor I	Design Con	ditions:	105	72		XX	65
Space Area:		370		(Sqft)	Indoor D	esign Cond	litions:	76	XX		50	67
Total Height		12		(Ft)	D	ifferrence:		29	XX		XX	-2
Volume 4440 Cu.ft.										¢		
ITEM	AREA Sun Gain /			Sun Gain /	U-FACTOR	Total	Daily Range (F) :					19
11 E.M	$\Delta T / CLT$ (Sqft) $\Delta T / CLT$			$\Delta T / CLTD$	(Btu/ F.hr.Ft ²)	(Btu/hr)	Duny runge					
		ROOM	SENSIB	LE HEAT		Correction for Temperature Difference (F):						14
Solar Gain - Glas	S N	}	0.0	22 F	0.75	By Pass Factor (BF):						0.1
GLASS	N NE		Sqft	23 F	0.75	0	Contact Fact	or (CF):				0.9
GLASS	F		Sqn	12 г 163 F	0.75	0	Light Load (WU/Saft) ·				4 2
GLASS	SF		Saft	105 F	0.75	0	Equipment I	oad (w):				1838
GLASS	S	74	Saft	12 F	0.75	666	Equipment E	ouu (11) .	OUTS	SIDEAIR		
GLASS	SW		Saft	85 F	0.75	0	CFM Per Per	son	25		7	175
GLASS	W	108	Saft	163 F	0.75	13203	AREA IN SF	T	· /	370	0.25	92.5
GLASS	NW		Saft	138 F	0.75	0	Selected Vent	ilation (Cfm)	····/···			175
SKYLIG	HT	/	Saft	251 F	1	0		EF	E. ROOM SI	N. HEATFA	CTOR	
Solar & Trans Ga	in Through -	- Walls & R	oof		/		ERSH	3879	99.64			
WALL	N	/	Sqft	18	0.37	0	ERTH	4001	5.078		1	0.9696255
WALL	NE	1	Sqft	37	0.37	0			Apparatus D	ew Point (Al	DP)	
WALL	E	7	Sqft	37	0.37	0	Indicated AD	P (F)				55
WALL	SE	1	Sqft	43	0.37	0	Selected ADF	P(F)				55
WALL	S	156	Sqft	30	0.37	1732			🔨 Dehumidi	ified Ai <mark>r Ris</mark> o	e	
WALL	SW		Sqft	57	0.37	0		CFX	K(Trm - ADP	') =		18.9
WALL	W	120	Sqft	26	0.37	1154			DEHUMI	DIFIED CFM		
WALL	NW/door	0	Sqft	54	0.34	0	Room	Sensble		38799.64		1866.26455
ROOF		370	Sqft	52	0.1	1924	Demudified R	TOTAL CEM		20.79	1	2204 525
Trans Cain Eva	nt walle & E	Poof						TOTAL CFM	OFPERIC	FRATION		2204.525
All Glas	s	182	Saft	2.9	0.8	4222.4		DEHUMIDIFIED C FM PER SQFT			~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	5.043958244
Partition	-01		Sqft	24	0.48	0		SOFTPE	R TO NNAG	EOFREF.		99.05169602
SKYLIG	IT		Sqft	29	0.45	0	U- Valu	es from Archi	tectural/		FINAL	RESULT
Partition	02		Sqft	24	0.48	0	St	ructural Drawi	ngs	/	TMBH	44.825078
Ceiling			Sqft	24	0.52	0	Glass Solar	Gain Coef.	0.75	4	SMBH	43.82364
Floor			Sqft	24	0.52	0	Glass I ran	s Gain Coer.	0.8		CFM EA (afm)	2204.525
Infilteration		29	1	29	1.08	908	Exten		0.57		FA (CIIII)	1/5
Ventilation		175	cfm	29	1.08	5481	R	oof	0.69			
Internal Heat							Ceiling	/ Floor	0.52			
Peoples	Peoples 7 No.s		No.s	245	2/6	1715	Part	ition	0.48			
Lights	ļ	370	Sqft	3.4	2	2516	DC	DOR	0.34			
Equipments	neihle Subt	515 515	I W	5.4	Subtotal	35272 /	inotes :	Notes : The II Values must not avecad Municipality Value				
Safety Factor	Isible Subt				10%	352724	Roof area should be added if roof is exposed to su			pairty values.		
Effective Room Se	nsible Heat	(SBH)			Total	38799.64		1001 0100			iposed to stair	
		ROOM	1 LATEN	T HEAT	s	·						
Ventilation		175	cfm	-2	0.68	-238		1MI	BH=1000 BT	U/HR		
Infilteration		29		-2	0.68	-39.44		I T	HERM=100 M	ИBH		
People	;	7	No.s	205	1	1435	-					
APPLIANCES 0		0	Subtatal	1157.56	-							
Safety Factor			5%	57,878	-							
Effective Room Latent Heat				Total	1215.438	~						
EFFEC TIVE ROOM TO TAL HEAT			Total	40015.078								
O UTSIDE AIR HEAT (VENTILATION					2	1						
SENSIBLE	175	cfm	29		0.99	5024						
LATENT	175	cfm	-2		0.612	-214						
Grand Total Heat S	ıbtotal	······	,		Subtotal	44825.078	_					
Safety Factor				0%	0							
	GRAND TO TAL HEAT					44825.078		1		1		

International Journal of Science and Research (IJSR) ISSN (Online): 2319-7064 Index Copernicus Value (2015): 78.96 | Impact Factor (2015): 6.391

PERFORMA OF E-20 OF OVERALL PROJECT

20 N LATITUTE												
PROJECT DETAILS								CONDITIO	NS - HYDE	RABAD		
Project Name	MINI P	ROIFCT	Data			DESIGN	DBT (F)	WBT(F)		BH (%)	HR (Cr/lb)	
Space:		OVERALL	BUILDIN	IG	Outdoor Design Condit		litions	105	72			65
Space.		11624.5	Deillon	(Saft)	Indoor Design Colla		tions.	76	72 VV		50	63
Space Area:		11034.5		(Sqn)	Indoor Design Condit		itions:	/0	лл		50	0/
Total Height	ight 12			(Ft)	D	ifferrence:		29	XX		XX	-2
Volume 139614 Cu.ft.												
ITEM	Sun Gain /	U-FACTOR	Total	Daily Pance (E) ·				10			
11 Elvi		(Sqfi	t)	$\Delta T / CLTD$	(Btu/ F.hr.Ft ²)	3tu/ F.hr.Ft ²) (Btu/hr)						19
		ROOMS	SENSIBI	LE HEAT			Correction fo	r Temperatur	e Difference (F) :		14
Solar Gain - Glass							By Pass Facto	or (BF) :				0.1
GLASS	N	633	Sqft	23 F	0.75	10919	Contact Facto	or (CF) :				0.9
GLASS	NE		Sqft	12 F	0.75	0	Occupancy (No.s) :				4
GLASS	E	1056	Sqft	163 F	0.75	129096	Light Load (W/Sqft) :				2
GLASS	SE		Sqft	12 F	0.75	0	Equipment Lo	oad (w) :	0.1100			1838
GLASS	S	674	Sqft	12 F	0.75	6066			OUIS	IDEAIR		
GLASS	SW		Sqft	85 F	0.75	0	CFM Per Per	son	25		246	6150
GLASS	W	375	Sqft	163 F	0.75	45844	AREA IN SFI	1		11634.5	0.25	2908.625
GLASS	NW		Sqft	138 F	0.75	0	Selected Vent	ilation (Cfm)				2908.625
SKYLIGH	IT		Sqft	251 F	1	0		EF	F. ROOM SE	N. HEAT FAC	CTOR	
Solar & Trans Gai	n Through -	Walls & Re	oof				ERSH	7132	90.38			0.020072025
WALL	N	465	Sqft	18	0.37	3097	ERTH	7670	000.4			0.929913933
WALL	NE		Sqft	37	0.37	0		/	Apparatus De	ew Point (Al	OP)	
WALL	E	462	Sqft	32	0.37	5470	Indicated AD	P (F)	ļ			55
WALL	SE		Sqft	43	0.37	0	Selected ADP	(F)				55
WALL	S	444	Sqft	30	0.37	4928			Dehumidi	fied Air R <mark>ise</mark>		
WALL	SW		Sqft	57	0.37	0		CFX	K(Trm - ADP) =		18.9
WALL	W	880	Sqft	26	0.37	8466			DEHUMI	DIFIED CFM		
WALL	NW/door	0	Sqft	54	0.34	0	Room	Sensble	<u></u>	713290.38		34309.30159
ROOF		<u>11</u> 634.5	Sqft	49	0.1	57009	Demudified Ri	SEXSP. HEAT		20.79	1	10505.0605
Turne Cala Free			/					TOTAL CFM				
All Glass	pt walls & R	2730	Saft	20	0.8	63511.8	DEHUMIDIFIED CEM PER SOFT					70.57895
Partition-(, 0.1	2139	Saft	2.9	0.48	0	SOFT PER TO NNAGE OF REF.				164 8437672	
SKYLIGH	T		Saft	29	0.45	0	U- Valu	es from Archi	tectural/		FINAL	RESULT
Partition-(02	/	Sqft	24	0.48	0	St	ructural Drawi	ngs		TMBH	846.9474
Ceiling		/	Sqft	24	0.52	0	Glass Solar	Gain Coef.	0.75		SMBH	796.79738
Floor			Sqft	24	0.52	0	Glass Trans Gain Coef. 0.8		0.8		CFM	40527.8625
Outside Air				/			Extern	al Wall	0.37		FA (cfm)	2908.625
Infilteration		310		29	1.08	9709	D	C.	0.50			
Ventilation		2908.625	cfm	29	1.08	91098	Coiling	/ Floor	0.69			
Recorder	1	246	Nos	245		60270	Part	ition	0.32			
Lights		11634.5	Saft	3.4	2	79115	DO	OR	0.48			
Equipments		21710	W	3.4	1	73814	Notes :	/				
Effective Room Ser	Effective Room Sensible Subtotal			Subtotal	648445.8		The U-Val	ues must not e	exceed Munic	ipality Values.		
Safety Factor					10%	64844.58	Roof area should be added if roof is exposed to sun.					
Effective Room Ser	nsible Heat	(SBH)			Total	713290.38						
· · · · · · · ·		ROOM	LATEN	T HEAT				1				
Ventilation		2908.625	cfm	-2	0.068	-396		1 M I	3H=1000 BTU	J/HR		
Infilteration Pearle		310		-2	0.68	-421.6		IT.	HERM=100 N	1BH		
ADDI LANCES		246	NO.S	205	1	50430				/		
Effective Room La	1340	Subtotal	51152.4		1 /	()	/					
Safety Factor					5%	2557.62						
Effective Room Latent Heat					Total	53710.02						
EFFEC TIVE ROOM TO TAL HEAT					Total	767000.4						
	ENTILATION				. ()	V /						
SENSIBLE	2908.625	¢fm	29		0.99	83507			2 /			
LATENT	2908.625	¢fm	-2		0.612	-3560	~	2.				
Grand Total Heat Su	btotal				Subtotal	846947.4		<u> </u>	/			
Safety Factor					0%	0		/				
	GRAND T	O TAL HEAT	ſ		Total	846947.4						

The heating load calculation of the project is calculated The BTU per hour for space 101 is 44825.

12000 BTU per hour is equal to 1 ton of refrigeration. Therefore, the calculated tonnage for the room no. 101 is (44825)/12000 = 3.51Tr

The BTU per hour for overall space is 846947. 12000 BTU per hour is equal to 1 ton of refrigeration Therefore, the calculated tonnage for the overall space is (846947)/12000 = 70.57tr

5. Conclusion

Using E-20 as per ISHRAE standards we provide effective comfort solution for the commercial building during summer, for that building heat absorption to be 846000BTUH.

Building Infiltration - 9288 BTUH

Room semsible heat – 713290 BTUH Room latent heat – 53710 BTUH Room total heat – 767000 BTUH Grand total Heat – 846947 BTUH

The Psychometric condition of a space after cooling load calculation is done.

WWW.ijsr.ner

Online): 2319



At point 1 Dry bulb temperature is 105 F Wet bulb temperature is 72 F

At point 2 Dry bulb temperature is 76 F Relative humidity is 50%

References

- [1] Milne, M, et al., Climate Consultant 40 Develops Design Guidelines for Each Unique Climate," proceedings of the American Solar Society. Buffalo New York, 2009.
- [2] Givoni, b., Man Climate and Architecture, Van Nostrand Reinhold, 1981.
- [3] Givoni, B., Climate Considerations in building and Urban Design. John Wiley and Sons, New York, 1998.
- [4] Driscoll, M. P., Psychology of learning for Instruction. Pearson Education, Florida State University, 2005.